



Benchmark Preventative Maintenance Kits

The beginning of the heating season is the ideal time to perform preventative maintenance. By our estimate, less than half of our customers perform such preventative maintenance, contributing to premature failure of components and unnecessary shut downs during the heating season.

To perform the necessary tasks indicated in the maintenance schedule of the Benchmark O&M, AERCO offers a complete line of annual and 24 month waterside/ fireside inspection kits.

- The annual maintenance kits consist of the Spark Ignitor, Flame Detector, and condensate trap orifice and o-ring.
- The 24-month waterside/fireside inspection kits consist of the Spark Ignitor, Flame Detector, and condensate trap orifice and o-ring, and gaskets/seals needed to inspect the fireside and waterside.

NOTE: This kit already includes the components included in the annual maintenance kit — therefore, when performing the waterside/fireside inspection, you only need the 24-month waterside/fireside inspection kit, not both

Estimated Labor Time:

- Maintenance Kits: 30 minutes
- Fireside Inspection Kits: 1-2 hours (dependent on kit)

Maintenance Kit	Part Number
2.0 Nozzle Mix Annual	124930
BMK Low NOx (ALL Sizes) Annual	58015-01
2.0 Nozzle Mix (24-mon insp.)	58015-02
2.0 LN (Orig Design) (24-mon insp.)	58015-03
3.0 (24-mon insp.)	58015-04
1.5 (24-mon insp.)	58015-05
2.0 LN (New Design) (24-mon insp.)	58015-06

For further information visit www.aerco.com.

Picture shown:
3.0 (24-month Inspection Kit)
part # 58015-04

